



Light quality control


### GL SpectroSoft Flicker Report

Measurement name: 2024-09-23T17:51:23  
Measurement time: 2024-09-23 17:51:23  
Report time: 2024-09-23 17:52:04

Client name: Azzardo Ligthing  
Model name: Alfa Mitus Track Magnetic 2line 18W  
CCT Switch  
Item No: AZ6257  
Serial No.:  
Made by: John Smith

Flicker	98,77 Hz
Flicker index	0,005875
Flicker percent	5,76 %
SVM	0,0034
SAM	-4,83
Mp	0,13
VESA flicker	-59,25
JEITA flicker	-62,26
PstLM	0,143


#### Flicker chart



#### FFT chart



Light quality control






Light quality control


### California's JA10 Test Method

Flicker percent 1000 Hz	1,112
Flicker percent 400 Hz	0,782
Flicker percent 200 Hz	0,551
Flicker percent 90 Hz	0,237
Flicker percent 40 Hz	0,187

#### FFT filtered 1000 Hz




#### FFT filtered 400 Hz






Light quality control

### FFT filtered 200 Hz



### FFT filtered 90 Hz



### FFT filtered 40 Hz



## Light quality control

