



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-09-20T10:53:13
Measurement time: 2024-09-20 10:53:13
Report time: 2024-09-20 10:55:09

Client name: *Azzardo Ligthing*
Model name: *Alfa Kerry Track Magnetic 2line 7W CCT Switch*
Item No: *AZ6255*
Serial No.:
Made by: *John Smith*

Flicker	2378,33 Hz
Flicker index	0,005986
Flicker percent	5,64 %
SVM	0,003
SAM	2,44
Mp	0,096
VESA flicker	-63,06
JEITA flicker	-66,07
PstLM	0,141


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,203
Flicker percent 400 Hz	0,711
Flicker percent 200 Hz	0,481
Flicker percent 90 Hz	0,235
Flicker percent 40 Hz	0,176

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

