



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-10-02T13:05:21
Measurement time: 2024-10-02 13:05:21
Report time: 2024-10-02 13:06:36

Client name: *Azzardo Ligthing*
Model name: *Alfa 2Line Saga Corner A 24W CCT*
Switch *DIMM*
Item No: *AZ6244*
Serial No.:
Made by: *John Smith*

Flicker	49,90 Hz
Flicker index	0,00637
Flicker percent	6,19 %
SVM	0,0038
SAM	-3,13
Mp	0,069
VESA flicker	-65,56
JEITA flicker	-68,57
PstLM	0,142


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,140
Flicker percent 400 Hz	0,692
Flicker percent 200 Hz	0,590
Flicker percent 90 Hz	0,353
Flicker percent 40 Hz	0,145

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

