



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-06-07T16:44:33
Measurement time: 2024-06-07 16:44:33
Report time: 2024-06-07 16:46:00

Client name: Azzardo Ligthing
Model name: Alfa Saga 12W Smart
Item No: AZ4846
Serial No.:
Made by: John Smith

Flicker	2235,15 Hz
Flicker index	0,006846
Flicker percent	6,43 %
SVM	0,0031
SAM	2,47
Mp	0,069
VESA flicker	-61,49
JEITA flicker	-64,50
PstLM	0,140


Flicker chart



FFT chart



Light quality control






Light quality control


California's JA10 Test Method

Flicker percent 1000 Hz	1,084
Flicker percent 400 Hz	0,713
Flicker percent 200 Hz	0,450
Flicker percent 90 Hz	0,265
Flicker percent 40 Hz	0,157

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

