



Light quality control


GL SpectroSoft Flicker Report

Measurement name: 2024-09-28T11:45:53
Measurement time: 2024-09-28 11:45:53
Report time: 2024-09-28 11:47:47

Client name: Azzardo Ligthing
Model name: Alfa DALI Niko 2 Track Magnetic 2x7W
CCT Dimm
Item No: AZ6293
Serial No.:
Made by: John Smith

Flicker	861,86 Hz
Flicker index	0,03822
Flicker percent	17,15 %
SVM	0,062
SAM	1,94
Mp	0,17
VESA flicker	-55,60
JEITA flicker	-58,61
PstLM	0,283


Flicker chart



FFT chart




Light quality control




California's JA10 Test Method

Flicker percent 1000 Hz	7,131
Flicker percent 400 Hz	0,990
Flicker percent 200 Hz	0,557
Flicker percent 90 Hz	0,409
Flicker percent 40 Hz	0,321

FFT filtered 1000 Hz




FFT filtered 400 Hz






Light quality control

FFT filtered 200 Hz



FFT filtered 90 Hz



FFT filtered 40 Hz



Light quality control

